

INDEX: ☐ YES ☐ NO ☐ CLASSIFIED MESSAGE ☒ TOTAL COPIES 23

CLASSIFY TO FILE NO. _____

X-REF TO FILE NO. _____

FILE RID ☐ RET. TO BRANCH ☐

DESTROY ☐ SIG. _____

SECRET

GROUP 1
EXCLUDED FROM AUTOMATIC
DOWNGRADING AND
DECLASSIFICATION

REPRODUCTION PROHIBITED

| | | | |
|---|--|---|----|
| 1 | | 5 | |
| 2 | | 6 | RE |
| 3 | | 7 | |
| 4 | | 8 | |

PERSON/UNIT NOTIFIED

ACTION

ADVANCE COPY

☐ RID COPY

☐ ISSUED ☐ SLOTTED ☐ TUBED

UNIT

TIME

BY

INFO

FILE, VR, [REDACTED] Kops 4

25X1A

SECRET 270327Z CIT [REDACTED] 0459

27 DEC 67 11 16 876 25X1A

B. DIRECTOR 45417

25X1A

1. IN ORDER PROCEED WITH B [REDACTED] A/C AND POWER PLANT PROJECTS ASAP, REQUEST COMMENTS ON REF A DESIGNS BE FORWARDED VIA CABLE.

2. MAJOR DESIGN DISCREPANCY NOTED THIS END IS OMISSION OF REF B 167 KVA, 208 VOLT DISTRIBUTION TRANSFORMERS TO UPDATE EXISTING 100 KVA UNITS. REFER TO SHEET 13 OF POWER PLANT DRAWINGS.

3. THE 167 KVA TRANSFORMERS EXTREMELY DESIRABLE TO PRECLUDE TRANSFERRING THE UPS LOAD TO 235 KW GENERATOR IN EVENT UPS IS DOWN FOR PROLONGED PERIODS.

4. AS FUNDS ARE AVAILABLE FOR 167 KVA UNITS PER REF B, PLAN DIRECT [REDACTED] TO INCLUDE THEM IN FINAL DESIGN.

5. FYI: OUR REVIEW BOTH PROJECTS NEARLY COMPLETED. WILL MEET WITH [REDACTED] AND A AND E SOON AS COMMENTS RECEIVED FROM YOU.

SECRET

SECRET

OC-E [REDACTED] will send an

Interim reply - pending our completion of a review by [REDACTED] R G W.

| |
|--------------|
| REC'D |
| C |
| DCP 12/27/67 |
| EX 12/27/67 |
| C/AC |

2

[REDACTED]

FILE

25X1A

ILLEGAL

25X1A